



QUICK APPLICATION

The hood(s) shall contain a factory engineered and pre-piped, UL Listed, Wet Chemical, Amerex® KP restaurant fire suppression system. The system piping shall be installed in the hood at the time of construction above the hood or within the supply plenum, and shall be concealed from view. No exposed piping is acceptable, with the exception of appliance drops. The system shall be capable of automatic detection and actuation and/or remote manual actuation. The system shall have the fire suppression capabilities to protect the duct(s), plenum(s), filter area(s) and cooking equipment.

The **Prepipe only** system includes schedule 40 black iron pipe, detectors, and chrome appliance drops. The remainder of the system is *not included* and is provided by others. Available for any jobsite.

The **US** system includes all parts to complete the system as well as field installation and certification. Mechanical or electrical gas valves shall be available for gas line shut-off applications and two (SPDT) single pull double throw microswitches for activation of the shunt trip breaker (provided by others) for electrical equipment. The system shall also include the MRM mechanical release module, agent cylinder, agent, detectors, fusible links or pneumatic tubing, liquidtight fittings, remote manual pull station, and schedule 40 black iron pipe with chrome sleeving for exposed areas. A certified local Amerex® distributor shall be selected by the factory for final system hook-up.

The **Export** system includes schedule 40 black iron pipe, detectors, chrome appliance drops, additional conduit and black iron to complete the system, the MRM mechanical release module, agent cylinder, agent, detectors, fusible links or pneumatic tubing, liquidtight fittings, remote manual pull station and gas valve. The field installed parts will be shipped to the freight forwarder by the manufacturer in a separate shipment. The remainder of the system is *not included* and is provided by others.

Due to continuous research Greenheck reserves the right to change specifications without notice.

Amerex® KP Wet Chemical Fire Suppression System

Type:

- Wet Chemical - Amerex® Zone Defense™ Kitchen Protection System**

Style:

- Prepipe (Any US or Export Jobsite)**
- US (Continental United States Only)**
- Export (Any jobsite outside the Continental United States)**

STANDARD FEATURES:

- UL and ULC Listed - Meets UL 300 requirements
- Liquidtight fittings for all hood penetrations where fully welded
- Low pH agent
- Reliable cartridge activated
- Chrome appliance drops

OPTIONS:

- Mechanical Gas Shut-Off Valves**
 - ___ 3/4 in. (19 mm) ___ 1 in. (25 mm) ___ 1 1/4 in. (32 mm)
 - ___ 1 1/2 in. (38 mm) ___ 2 in. (50 mm) ___ 2 1/2 in. (64 mm)
 - ___ 3 in. (76 mm)
- Electrical Gas Shut-Off Valves**
 - ___ 3/4 in. (19 mm) ___ 1 in. (25 mm) ___ 1 1/2 in. (38 mm)
 - ___ 2 in. (50 mm) ___ 3 in. (76 mm)
- No Gas Valve (for electrical cooking appliance line-ups only)**



The **Wet Chemical Fire Suppression System** is ideally suitable for use in restaurants, hospitals, nursing homes, hotels, schools, airports and other similar facilities.

The system discharges wet chemical onto the hazard area with all nozzles discharging simultaneously. The agent reacts with the hot grease to form a layer of foam that insulates the grease from the air, and helps prevent flame reignition

Code Information

The Amerex® KP Restaurant Fire Suppression System is constructed in compliance with the following:

- **National Fire Protection Association (NFPA) Bulletin #96 and #17A**
- **UL Standard 300 Listed**
- **ISO 9001-2000**



This program applies only to the continental United States

The basic wet chemical fire suppression system includes the following:

- Pre-piping of the kitchen hood with schedule 40 black iron pipe
 - Fuel shut-off device:
 - A. *Choice of a mechanical gas valve, or
 - B. *Choice of an electrical gas valve with a manual reset relay.(The installation of the valve is the responsibility of the plumbing contractor)
 - Two single-pole, double throw microswitches are provided for use with electric appliances. This device can also be used with alarm systems, fan shut down, and electric gas solenoid valves. (The wiring of this device is the responsibility of the electrical contractor.)
 - All detectors, links or pneumatic tubing*, release mechanism, tank and fire suppression agent*.
 - One manual pull station for remote surface mounting. (this must be in the path of egress, at a maximum distance of 20 ft. (6.1 meters) from the release mechanism)
 - An Amerex® tank and release mechanism (for remote mounting only).
 - Final field hook-up* to be performed by a non-union certified Amerex® distributor.
 - Greenheck Hood Mounted Fire Cabinet Hook-Up to consist of:
Hook-up of detection lines, hook-up of supply lines, mount and hook-up of remote manual pull, hook-up of mechanical gas valve (if applicable), and tag system.
 - Greenheck Remote Mounted Fire Cabinet Hook-Up to consist of:
Hang MRM release and additional tanks if multiple system, hook-up of detection lines, hook-up of supply lines, mount and hook-up of remote manual pull, hook-up of mechanical gas valve (if applicable), tag system.
Factory coordination of final system hook-up between jobsite contact and the assigned Amerex® distributor.
 - Three trips out to the jobsite is included.
 - Any state or local installation permits
 - Puff or Air test
- * Items supplied by the assigned Amerex® distributor

The basic wet chemical fire suppression system does not include the following:

- Special drawings required by state or local codes
- Full dump test, testing other than what is specified on the restaurant system installation manual, or special requirements to satisfy a state or local code
- Union labor, government labor, or prevailing wages required for final field hook-up
- Special classes or additional labor for access to security sensitive areas
- Installation of the gas shut-off valve (gas piping connections)
- Rough-in of hidden conduit for remote pull stations (flush mount) or gas valves
- Installation of more than one (1) remote pull station per system
- Pull stations installed at a distance greater than 20 feet (6.1 meters)
- Release modules and tanks installed at a distance greater than 60 inches (1.5 meters).
- The cost of and installation of any electrical shut-off hardware other than the snap action switch, manual reset relay or pressure switch (i.e. shunt trip breaker or electrical contactors)
- All electrical connections required fan shutdown, shut down of electric cooking equipment, connections from the restaurant system to any fire alarm control panel or system
- More than three trips to the jobsite or special transportation, or overnight lodging required for hook-ups in remote locations (normal travel distance is defined as the first 50 miles (80.5 km) from the distributor's office)
- Any dismantling or reassembly required to gain access to the fire suppression piping located on top of the hood.
- Parts or labor required to correct piping due to cooking equipment changes or deviations from plans
- Any charges for missing or additional parts other than those indicated on the attached fire suppression detail

Note: The customer is responsible for and will be invoiced separately for any additional parts or services not covered in the above items.